

ADDENDUM NO. 1

Construction Renovations of The Freedom Park Restroom and Snack Bar Facility

July 14, 2026

This Addendum form is a part of the Contract Documents for the above-identified project and modifies the original Specifications and Contract Documents, as noted on the following pages. Portions of the Contract, not specifically mentioned in this Addendum, remain in force. All trades affected shall be fully advised of these changes, deletions, and additions.

The proposal due date is 12:00pm on July 15, 2026.

Matthew Parker
Park Services Manager
Pleasant Valley Recreation and Park District

PROPOSER'S CERTIFICATE

I acknowledge receipt of all two (2) pages of this Addendum No.1 and accept the aforementioned.

Proposer's Signature

Date

**THIS DOCUMENT TO BE SIGNED
AND SUBMITTED WITH PROPOSAL**

Construction Renovations of The Freedom Park Restroom and Snack Bar Facility

July 14, 2026

ADDENDUM NO. 1

The following additions and/or corrections shall become a part of the Contract Documents and Specifications for the above-named project. When submitting a proposal for the project, this Addendum shall be acknowledged, and ***a signed copy of the Addendum shall be included in the proposal package.***

Changes or clarifications are noted are BOLD and UNDERLINED

I. GENERAL

The proposer is directed to make the following corrections, deletions, and/or additions to the contract documents and contract drawings heretofore dispensed to him for the above project, and to note proposer's receipt of this addendum by number on the attached ***Addenda Acknowledgement Form:***

II. MODIFICATIONS TO PREVIOUS ADDENDA **N/A**

III. Response to RFI

Freedom Park Restroom and Snack Bar Facility RFQ:

- Is the City of Camarillo utilizing a project Labor Agreement (PLA)? **No**
- Is the Consultant required to maintain a List of Pre-Qualified Contractors? **No**
- Can the Consultant utilize Procore Management Software for this project, or does the City of Camarillo stipulate the use of specific Construction Management Software? **No software specified, you can use PROCORE.**
- Will the City of Camarillo require the Consultant to provide a Labor Compliance officer? **No**
- Will the City of Camarillo require the Consultant to provide Professional Services, e.g., Engineering, MEP, and Environmental testing? **No,**
- Did the City of Camarillo perform a camera video recording of the existing waste and sewer lines? If so, can you please share the Video? **Not yet, and we will provide video once completed.**
- Please provide clarification regarding the provisions for emergency power.

For rooms having (1) required exit minimum and with egress path of travel less than 75' to their respective exits, **emergency lighting is not required.**

When submitting a proposal for the project, this Addendum shall be acknowledged, and a signed copy of the Addendum shall be included in the proposal package.